

OFFICE USE ONLY
 Log No. **39509**
 Permit No. **3**
 Basin **89-WASHOE VALLEY**
 NOTICE OF INTENT NO. **19662**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Christopher Miller ADDRESS AT WELL LOCATION Franktown Rd
 MAILING ADDRESS 1009 N Curry St
Carson City, Nv 89701

2. LOCATION NW 1/4 SW 1/4 Sec. 22 T. 15 16 N/S R. 19 E Washoe County Washoe
 PERMIT NO. 55-200-63 Subdivision Name Washoe Valley
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	1	1
Red brown clay & D.G.		1	15	15
cobbles boulders		15	17	2
D.G. & Pyrite		17	57	40
Really fractured D.G.		57	63	6
Soft D.G. fractured		63	87	24
Clay gray & red brown & D.G.		87	103	16
Granite & Pyrite		103	298	195
Fractured grandodirite		298	450	152
T.D. 450 ft				

8. WELL CONSTRUCTION
 Depth Drilled 450 Feet Depth Cased 450 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12	0	50
10	50	298
7 7/8	298	450

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+ 1	298
6 5/8	12.92 & 14.98	.188 & .219	290	450

Perforations: double - factory
 Type perforation 3/32" X 3' & torch cut
 Size perforation

From	To
238 feet	278 feet
410 feet	430 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 298 feet

9. WATER LEVEL
 Static water level 20 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431
 Nevada contractor's license number issued by the State Contractor's Board 15291
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1804 & 1132
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date 8/24/92

Date started 6/1/92, 19_____
 Date completed 8/11/92, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Major System Pumping Test	<u>50+</u>	<u>67.1</u>	<u>2</u>
<input type="checkbox"/> Minor System Pumping Test			
<input type="checkbox"/> Air Lift			