

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19367

1. OWNER Richard H. Holbrook ADDRESS AT WELL LOCATION SAME
MAILING ADDRESS 14 E. PURSIEH LN.
VERMONT TOWN, NEV. 89447
2. LOCATION SW 1/4 SE 1/4 Sec. 36 T. 13 S R. 25 E LYON County
PERMIT NO. _____ Issued by Water Resources Parcel No. N/A Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Clay		0	4	4
Coarse Sand		4	32	28
Clay + Coarse Sand		32	36	4
Coarse Sand		36	63	27
Coarse Sand, Gravel				
Few Rock		63	73	10
Coarse Sand, Gravel		73	86	13
Coarse Sand				
Gravel + Rock		86	95	9
Clay		95	108	13
Coarse Sand + Small Gravel		108	125	17
Coarse Sand + Clay		125	134	9
Clay + Coarse Sand		134	142	8
Coarse Sand + Small X				
Gravel with Clay				
Strata		142	160'6"	18'6"

8. WELL CONSTRUCTION
Depth Drilled 159'6" Feet Depth Cased 160'6" Feet

HOLE DIAMETER (BIT SIZE)
From _____ To _____
11 Inches _____ Feet 159'6" Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>.108</u>	<u>1</u>	<u>159'6"</u>

Perforations:
Type perforation Sawed
Size perforation 1/8" x 3" x 6 Rows
From 159'6" feet to 159'6" feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 159'6" feet

9. WATER LEVEL
Static water level 79'6" feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality Good

Date started 7-20 1992
Date completed 7-23 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailed</u>	<u>25</u>	<u>84</u>	<u>42 HRS</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling Contractor
Address 162 N. Bybee Lane Contractor
Yerington Nev 89445
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Lay Ogden
By driller performing actual drilling on site or contractor
Date 7-29-92

OFFICE USE ONLY
Log No. 39520
Permit No. _____
Basin 9-108

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19367
ADDRESS AT WELL LOCATION 14 E Parsel Lane
Yerington Nev 89442

1. OWNER Richard Holbrook
MAILING ADDRESS 14 E Parsel Lane
Yerington Nev 89442
2. LOCATION SW 1/4 SE 1/4 Sec 36 T 13 S R 25 E Lyon County
PERMIT NO. 12-151-04
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Clay		0	4	4
Coarse Sand		4	28	24
Clay - Coarse Sand		28	36	8
Coarse Sand		36	63	27
Coarse Sand-Gravel				
Few Rocks		63	73	10
Coarse Sand-Gravel		73	86	13
Coarse Sand-Gravel				
Rock		86	95	9
Clay		95	108	13
Coarse Sand - Small Gravel		108	125	17
Coarse Sand - Clay		125	134	9
Clay - Coarse Sand		134	142	8
Coarse Sand - Small Gravel - with Clay Strats	X	142	160	18'

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 161'6" Feet
HOLE DIAMETER (BIT SIZE)
From To
11 Inches 0 Feet 160 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Fect)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>71.5</u>	<u>160</u>

Perforations:
Type perforation Sawed
Size perforation 3/22 x 3" x 6 Rows
From 140 feet to 160 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 79'6" feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling Contractor
Address 162 N. B. Bee Lane Contractor
Yerington Nev 89442
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Ray Ogden
By driller performing actual drilling on site or contractor
Date July 25, 1992

Date started July 20, 1992
Date completed July 23, 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailed</u>	<u>25</u>	<u>5</u>	<u>1/2</u>