

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10022

1. OWNER EDITH L THRELKELD ADDRESS AT WELL LOCATION Corner of 5th
 MAILING ADDRESS Unit 187-15 And Carl Creek Road lot 2 Bk 25
RYNDON

2. LOCATION SE 1/4 NW 1/4 Sec. 31 T. 36 N/S R. 56 E. 110 County
 PERMIT NO. 30-025-02-7 Parcel No. MUR # 1 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Loam</u>		<u>0</u>	<u>6</u>	<u>26</u>
<u>Hard SANDSTONE</u>		<u>6</u>	<u>46</u>	<u>40</u>
<u>CLAY</u>		<u>46</u>	<u>63</u>	<u>17</u>
<u>Clay mix with SAND</u>	<u>Water</u>	<u>63</u>	<u>100</u>	<u>37</u>
<u>STONE</u>				

'92 SEP -9 AM 11:00
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10" Inches 0 Feet 100 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Fect)	To (Fect)
<u>6</u>	<u>12.92</u>	<u>1.88</u>	<u>7.2</u>	<u>100</u>

Perforations:
 Type perforation slots
 Size perforation 3/16" x 3"

From 8.4 feet to 100 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 55

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 55 feet to 100 feet

9. WATER LEVEL
 Static water level 14' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Co Contractor
 Address P.O. Box 525 Contractor
Elko NV 89803

Nevada contractor's license number issued by the State Contractor's Board 31904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shoultz Fertig
 By driller performing actual drilling on site or Contractor
 Date 8-18-92

Date started 8-17 1992
 Date completed 8-18 1992

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>45 +</u>		<u>3</u>