

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 39547  
 Permit No. 50  
 Basin 5

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 19207

1. OWNER JAMES A. PATTANT ADDRESS AT WELL LOCATION Approximately  
 MAILING ADDRESS 1009 Coont St Eleven miles north of Eiko on  
Eiko N.V. 89801 Highway 225  
 2. LOCATION SE 1/4 NW 1/4 Sec. 15 T 35 N/S R. 54 E Eiko County  
 PERMIT NO. 05-520-05-1 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<del>Black Clay</del> <u>BLACK CLAY</u>		<u>0</u>	<u>28</u>	<u>28</u>
<u>BLACK SANDSTONE</u>	<u>water</u>	<u>28</u>	<u>49</u>	<u>11</u>
<u>CLAY</u>		<u>49</u>	<u>66</u>	<u>17</u>
<u>SANDSTONE</u>		<u>66</u>	<u>95</u>	<u>29</u>
<u>Hard Rock</u>		<u>95</u>	<u>96</u>	<u>1</u>
<u>SAND &amp; Gravel</u>	<u>water</u>	<u>96</u>	<u>150</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 150 Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.92</u>	<u>1.88</u>	<u>+2</u>	<u>150</u>

 Perforations:  
 Type perforation SOFTS  
 Size perforation 3/4 x 3"  
 From 120 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal SA  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 52 feet to 150 feet

Date started 8-20, 1992  
 Date completed 8-24, 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>65</u>		<u>4</u>

9. WATER LEVEL  
 Static water level +1' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Good °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fertig Drilling Co Contractor  
P.O. Box 525 Eiko N.V. 89803 Address Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 31904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584  
 Signed Shouk Judge  
 By driller performing actual drilling on site or contractor  
 Date 9-20-92