

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20101

1. OWNER George Goldman ADDRESS AT WELL LOCATION 4920 FRANKTOWN RD  
 MAILING ADDRESS 6186 Laurel Wood Dr  
Reno, Nv 89509

2. LOCATION SW 1/4 NW 1/4 Sec 10 T 16 N/S R 19 E Washoe County Washoe  
 PERMIT NO. 055-033-01 Subdivision Name Washoe Valley  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  Cable  Rotary  RVC  
 Air  Other..... Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	2	2
Brown coarse sand with some fine brown rock		2	15	13
Multi-colored sands coarse decomposed		15	20	5
Brown coarse sand w/ fine brown sand		20	70	50
Brown clay w/ some coarse & fine sand		70	103	33
White black brown granite rock broken		103	130	27
White & blk granite rock med. hard		130	150	20
White & blk granite rock highly fractured		150	202	52
White clay [sticky]		202	204	2
Coarse white sands & fine brown sand		204	211	8
White clay & some course sands		211	220	9
T.D. 220 ft				

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
<u>10 5/8</u>	<u>0</u>	<u>52</u>
<u>8 1/2</u>	<u>52</u>	<u>220</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+ 1</u>	<u>220</u>

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3

From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 52  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 52 feet to 220 feet

9. WATER LEVEL  
 Static water level 12 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc Contractor  
 Address 625 Spice Islands Dr Suite L Sparks Contractor  
Sparks, Nv 89431  
 Nevada contractor's license number issued by the State Contractor's Board 15291  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1509  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 8/10/92

Date started 8/3/92  
 Date completed 8/4/92

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  AN LI

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>		<u>2</u>