WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39605
Permit No.
Basin 92A

NOTICE OF INTENT NO. 21647

1. OWNER MEL EVENS/AWARD INC.
MAILING ADDRESS P.O. Box 60515
Reno, NV 89506

ADDRESS AT WELL LOCATION
10385 Placerville Drive
Reno, NV 89506

2. LOCATION NW ¼ SE ¼ Sec. 13 T 21N N/S R 18 E Washoe County
PERMIT NO. (Issued by Water Resources) 086-252-8 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay w/ D.G.		1	6	5
Green fine sandy clay		6	11	5
Brown clay		11	57	46
Brown sandy clay		57	118	61
Soft zone (NO WATER)		118	121	3
Brown sandy clay		121	192	71
Soft zone	X	192	205	13
Brown sandy clay		205	222	17
Soft zone	X	222	230	8
Brown clay		230	241	11
Soft zone	X	241	243	2
Gray & blue clay		243	250	7

'92 SEP 28 P1:30
STATE ENGINEER

Date started 9-22-92, 19
Date completed 9-24-92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	250	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	250

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 190 feet to 210 feet
From 230 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 250 feet

9. WATER LEVEL
Static water level 165 feet below land surface
Artesian flow 17 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date September 24, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627