

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21332

1. OWNER Dividend Construction—Richard Hutchings ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 1915 4170 Bottom Road  
Fallon, Nevada 89407-1915 Fallon, Nev. 89406

2. LOCATION N/E 1/4 N/E 1/4 Sec. 32 T. 19 N/S R. 28 E. Churchill County  
 PERMIT NO. 08-691-65 Pheasant Green

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	10	10
Brown Coarse Sand		10	12	2
Brown Sandy Clay		12	14	2
Brown Coarse Sand		14	16	2
Brown Clay		16	22	6
Brown Coarse Sand		22	32	10
Brown Fine Sand		32	34	2
Gray Fine Sand		34	38	4
Brown Coarse Sand		38	48	10
Fine Gray Sand		48	51	3
Black Fine Sand		51	54	3
Fine Gray Sand		54	56	2
Black & Green Coarse Sand		56	64	8
Gray Fine Sand		64	73	9
Brown Fine Sand		73	76	3
Brown Clay		76	78	2
Brown Coarse Sand & Gravel	X	78	88	10

8. WELL CONSTRUCTION  
 Depth Drilled 88 Feet Depth Cased 88 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches 0 Feet To 88 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	88

Perforations:  
 Type perforation Mill Cut  
 Size perforation 1/8"  
 From 84 feet to 87 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 70ft.  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 70 feet to 88 feet

9. WATER LEVEL  
 Static water level 20' 6" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cool °F Quality Unknown

Date started Sept. 5 19 92  
 Date completed Sept. 5 19 92

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name PARSONS DRILLING, INC. Contractor  
 Address P.O. BOX 1265 Contractor  
FALLON, NEVADA 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715  
 Signed Doug Parsons  
 By driller performing actual drilling on site or contractor  
 Date Sept 11, 1992