

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20974

1. OWNER DAVE JOHNSON ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 636 THOROUGHbred GARDNERVILLE, NV 636 THOROUGHbred GARDNERVILLE, NV
 2. LOCATION SE 1/4 SE 1/4 Sec 24 T. 12 N. R. 20 E DOUGLAS County DOUGLAS
 PERMIT NO. 29-102-03 Parcel No. _____ Subdivision Name THOMPSON ACRES
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY, BOULDERS		0	12	12
CLAY		12	21	9
SANDY CLAY, BOULDERS		21	138	117
SANDY CLAY, COBBLES		138	219	81
SAND, GRAVEL, SOME CLAY	✓	219	260	41
SAND, GRAVEL	✓	260	275	15

8. WELL CONSTRUCTION
 Depth Drilled 275 Feet Depth Cased 275 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 120 Feet
8 3/4 Inches 120 Feet 260 Feet
5 5/8 Inches 260 Feet 275 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>260</u>
<u>5</u>	<u>11</u>	<u>.188</u>	<u>260</u>	<u>275</u>

 Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 X 3/32
 From 220 feet to 260 feet
 From 260 feet to 275 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 260 feet

Date started 8-17, 1992
 Date completed 8-27, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>15</u>	<u>—</u>	<u>1</u>

9. WATER LEVEL
 Static water level 160 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD
 10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD. FALLON, NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Pat J. Moore
 By driller performing actual drilling on site or contractor
 Date 8-27-92