WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39721
Permit No. 54656
Basin

NOTICE OF INTENT NO. 10722

1. OWNER P.K. ESTATES
MAILING ADDRESS
ADDRESS AT WELL LOCATION WIGWAM + DURANGO

2. LOCATION SW ¼ NW ¼ Sec. 16 T. 22 N/S R. 60 E. CLARK County
PERMIT NO. 54656 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND + ROCKS		0	20	20
CLAY, GRAVEL w/		20	310	290
STREAKS CEMENTED				
GRAVEL.				
CEMENTED GRAVEL		310	505	195
W/STREAKS OF CLAY				
BROWN LIME		505	515	10
CEMENTED GRAVEL		515	630	115
RED SAND STONE		630	710	80
CEMENTED GRAVEL		710	740	30
LIME STONE		740	800	60
CEMENTED GRAVEL		800	820	20

RECEIVED
JUL 30 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 6-29, 1992
Date completed 7-10, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	820 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+1	820

Perforations:
Type perforation FACTORY
Size perforation 1/8 x 3
From 760 feet to 800 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 820 feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DESERT DRILLING (Contractor)
Address 4545 N. RANCHO (Contractor)
LAS VEGAS, NEVADA 89130
Nevada contractor's license number issued by the State Contractor's Board 34274
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594
Signed Pindall Couch
By driller performing actual drilling on site or contractor
Date 7-24-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627