

OFFICE USE ONLY  
 Log No. 391778  
 Permit No. 1  
 Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20814

1. OWNER Mark Delany ADDRESS AT WELL LOCATION Mark Lane 3545  
 MAILING ADDRESS 416 W. 2nd. Street  
Winnemucca, Nevada 89445  
 2. LOCATION S.W. 1/4 S.W. 1/4 Sec. 10 T. 37 N. N/S R. 38 E. Humboldt County  
 PERMIT NO. \_\_\_\_\_ Parcel No. 06-481-46 Subdivision Name \_\_\_\_\_  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil brown.		0	2	2
Sand brown.		2	10	8
Clay brown.		10	28	18
Gravelly clay brown.		28	91	63
Clay brown w/strips of sand & gravel.	19	91	110	

8. WELL CONSTRUCTION  
 Depth Drilled 110 Feet Depth Cased 110 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
16 Inches 50 Feet 110 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>14</u>	<u>.188</u>	<u>0</u>	<u>110</u>

'92 AUG 21 AM 1:00  
 RECEIVED STATE ENGINEERS OFFICE  
 JAN - 7 1993  
 STATE ENGINEERS OFFICE

Perforations:  
 Type perforation torch  
 Size perforation 1/8" by 5"  
 From 90 feet to 110 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started Aug. 12, 1992  
 Date completed Aug. 14, 1992

7. WELL TEST DATA

TEST METHOD: <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>30</u>	<u>10</u>	<u>3</u>	

9. WATER LEVEL  
 Static water level 36 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 54 °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name T. & R. Drilling Contractor  
 Address P.O. Box 1982 Contractor  
Winnemucca, Nevada 89446  
 Nevada contractor's license number issued by the State Contractor's Board 017721  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1190  
 Signed Thomas [Signature]  
 By driller performing actual drilling on site or contractor  
 Date Aug. 17, 1992