



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 20917

1. OWNER LOGAN CREEK IMP DIST ADDRESS AT WELL LOCATION NONE
 MAILING ADDRESS Box 102
GLEN BROOK, NV 89413
 2. LOCATION NE NE 1/4 Sec 22 T 14 S R 18 E DOUGLAS County
 PERMIT NO. 15289/15290 NA LOGAN CREEK
Issued by Water Resources Parcel No Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
FOREST ALLUVIUM		0	4	4
V HARD GRANITE		4	176	172
FEW FRACTURES FRACTURED	X	176	191	15
HARD GRANITE		191	460	269
SOME FRACTURES FRACTURES, w LARGE FRAC FROM 540-560	X	460	580	120
ALTERED GRANITE 520-540				

8. WELL CONSTRUCTION
 Depth Drilled 580 Feet Depth Cased 570 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches 0 Feet 580 Feet
 Inches Feet Feet
 Inches Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>		<u>1/4 WALL</u>	<u>+2</u>	<u>575</u>

 Perforations:
 Type perforation SAUCUT
 Size perforation 3" x 3/32"
 From 120 feet to 575 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 102 Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 102 feet to 575 feet
 9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow No G.P.M. P.S.I.
 Water temperature COLD °F Quality ?

RECEIVED
 JAN 13 1993
 STATE ENGINEER'S OFFICE
 '92 OCT 27 P 4:16
 STATE ENGINEER'S OFFICE

Date started 8/31 1992
 Date completed 9/3 1992

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30-40</u>		<u>6 Hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING, INC Contractor
 Address Box 21548 Contractor
CC, NV 89721
 Nevada contractor's license number issued by the State Contractor's Board 13697A
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1539
 Signed Joe Reisch
 By driller performing actual drilling on site or contractor
 Date 10/26/92

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 20917

1. OWNER LOGAN CREEK IMP DIST ADDRESS AT WELL LOCATION NONE
 MAILING ADDRESS Box 102
GLEN BROOK, NV 89413

2. LOCATION NE 1/4 NE 1/4 Sec 22 T 14 S R 18 E DOUGLAS County
 PERMIT NO. NA Issued by Water Resources Parcel No. LOGAN CREEK Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FOREST ALLUVIUM		0	4	4
V HARD GRANITE		4	176	172
FEW FRACTURES FRACTURED	X	176	191	15
HARD GRANITE SOME FRACTURES		191	460	269
FRACTURES, w LARGE FRAC FROM 540-560	X	460	580	120
ALTERED GRANITE 520-540				

8. WELL CONSTRUCTION
 Depth Drilled 580 Feet Depth Cased 570 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches 0 Feet 580 Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>		<u>1/4 WALL</u>	<u>+2</u>	<u>575</u>

Perforations:
 Type perforation SAUCUT
 Size perforation 3" x 3/32"
 From 120 feet to 575 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 102

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 102 feet to 575 feet

9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow No G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality ?

Date started 8/31, 1992
 Date completed 9/3, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30-40</u>		<u>6 Hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NEVADA DRILLING, Inc Contractor
 Address Box 21540 Contractor
CC, NV 89721
 Nevada contractor's license number issued by the State Contractor's Board 13697A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1539

Signed Joe Leiseh
 By driller performing actual drilling on site or contractor
 Date 10/26/92