

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 20913

1. OWNER MIMI JOB ADDRESS AT WELL LOCATION 210 AUTUMN HILLS, GARDNERVILLE, NV
 MAILING ADDRESS 210 AUTUMN HILLS, GARDNERVILLE, NV
 2. LOCATION SW 1/4 SW 1/4 Sec 3 T. 12 N. R. 19 E DOUGLAS County FOOTHILL
 PERMIT NO. 19-051-20 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CONST FILL		0	2	2
V LARGE BLDGS IN DG		2	36	34
DG COARSE FEW CLAY BEDS, V THIN		36	165	129
DG ALTERED SOME O ₂ STAINS FEW LARGE COBBLES, AB DG SANDS	X	165	225	60
ABANDON EXISTING WELL WITH RIPPER, CEMENT SEAL W BENTONITE PELLETS AT BOTTOM 5 FT. FILL CASING W CEMENT GROUT.				

8. WELL CONSTRUCTION
 Depth Drilled 225 Feet Depth Cased 225 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 225 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>.188</u>	<u>+2</u>	<u>225</u>

Perforations:
 Type perforation SAUCUT
 Size perforation 3X 3/32
 From 165 feet to 225 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 225 feet

9. WATER LEVEL
 Static water level 163 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.0 °F Quality ?

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING, INC Contractor
 Address Box 21548 Contractor
CARSON CITY, NV 89720
 Nevada contractor's license number issued by the State Contractor's Board 13697A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
 Signed Joseph J. Reich
 By driller performing actual drilling on site or contractor
 Date 12/4/92

Date started 10/3 19 92
 Date completed 10/7 19 92

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20±</u>		<u>4</u>