

OFFICE USE ONLY
 Log No. 31802
 Permit No. 105
 Basin. 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20910

1. OWNER W. Coy ADDRESS AT WELL LOCATION 2291 MAIN ST GENOA, NV
 MAILING ADDRESS Pink House Restaurant 2291 MAIN ST GENOA, NV
 2. LOCATION NE 1/4 SE 1/4 Sec. 9 T. 13 N. R. 19 E DOUGLAS County
 PERMIT NO. 30105 NA Parcel No. NA Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ALLUVIUM	X	0	130	130
ABANDONED THE EXISTING WELL ON 10/30/92 JFL				

8. WELL CONSTRUCTION
 Depth Drilled 130 Feet Depth Cased 130 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 130 Feet
 Inches Feet
 Inches Feet
 Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 7/8		1.88	+0	130

Perforations:
 Type perforation SAWCUT
 Size perforation 3 X 3/32
 From 100 feet to 130 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 130 feet

9. WATER LEVEL
 Static water level 61 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.0 °F Quality ?

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING, INC Contractor
 Address Box 21548 Contractor
CARSON CITY, NV 89721
 Nevada contractor's license number issued by the State Contractor's Board. 13697A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
 Signed Joseph H. Feisch
 By driller performing actual drilling on site or contractor
 Date 12/4/92

Date started 10/28 1992
 Date completed 10/29 1992

7. WELL TEST DATA

TEST METHOD:		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>2.5</u>	<u>-</u>	<u>3</u>