WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39866
Permit No.
Basin 101

NOTICE OF INTENT NO. 21452

1. OWNER Val Roman
MAILING ADDRESS 7195 Stillwater Road
Fallon, NV 89406

ADDRESS AT WELL LOCATION 1285 Bianchi Road
Fallon, NV 89406

2. LOCATION NW ¼ SW ¼ Sec. 20 T 19 N/S R 29 E Churchill County
PERMIT NO. (Issued by Water Resources) 7-471-35 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	10	10
Brown Clay		10	13	3
Fine Brown Sand		13	29	16
Brown Coarse Sand		29	40	11
Green Fine Sand		40	45	5
Black & Green Sandy Clay		45	64	19
Black & Green Coarse Sand		64	73	9
Green Clay		73	76	3
Black & Brown Coarse Sand		76	84	8
Brown Coarse Sand	X	84	96	12

Date started December 7, 19 92
Date completed December 7, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 96 Feet Depth Cased 96 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	96 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	96

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 92 feet to 95 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 96 feet

9. WATER LEVEL
Static water level 27 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715

Signed Doug Parsons (By driller performing actual drilling on site or contractor)
Date Dec. 10, 1992

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627