


PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.100



NOTICE OF INTENT NO. 17963

1. OWNER KNIGHT PIESOLD  
 MAILING ADDRESS 1600 STOUT ST. SUITE #400  
DENVER, CO 80202  
 ADDRESS AT WELL LOCATION  
NEWMONT MINE NEAR CARLIN, NV

2. LOCATION SE 1/4 SW 32 T. 36 N. R. 50 E EUREKA County  
 PERMIT NO. WAIVER#M/O 225-A N/A  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

8. WELL CONSTRUCTION  
 Depth Drilled 123 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 8 Feet  
17 1/2 Inches 0 Feet 8 Feet  
11 Inches 8 Feet 120 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12-3/4	33	.25	0	8
5		SCH 80 PVC	0	120

Perforations:  
 Type perforation SLOT  
 Size perforation .010  
 From 96 feet to 115 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 120 feet to 79 feet

9. WATER LEVEL  
 State water level 69.4 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING Contractor  
 Address 2286 WEST 1500 SOUTH Contractor  
SALT LAKE CITY, UT 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976  
 Nevada driller's license number issued by the Division of Water Resources 1410  
 Signed John J. Hergutz  
 By driller performing actual drilling on site or contractor  
 Date NOVEMBER 29, 1992

Material	Water Strata	From	To	Thick-ness
SAND, GRAVEL, CLAY		0	123	123
<p><i>MAZ W-5B</i></p> <p><i>15</i></p> <p><i>120' T.D.</i></p> <p><i>W.L. = 68.57</i></p> <p><i>10/15/92</i></p> <p><i>CONV. DATE</i></p> <p><i>92 DEC -7 P2:55</i></p> <p><i>STATE ENGINEER</i></p>				

Date started NOVEMBER 27 1992  
 Date completed NOVEMBER 28 1992

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
3		