WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39913
Permit No.
Basin 27

NOTICE OF INTENT NO. 21172

1. OWNER WASHOE COUNTY UTILITY DIVISION
MAILING ADDRESS 1195 B. CORPORATE BLVD
RENO, NV 89502
ADDRESS AT WELL LOCATION WASHOE COUNTY UTILITY
1195 B CORPORATE BLVD
RENO, NV. 89502

2. LOCATION NW ¼ SW ¼ Sec. 16 T. 19 N/S R. 20 E. WASHOE County
PERMIT NO. M-0575 (Issued by Water Resources) Parcel No.
WASHOE COUNTY PERMIT NO.: 004603 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL, CLAY, SAND		0	7	7
SAND, FRACTURE ROCK		7	65	58
SAND, FRACTURE ROCK		65	93	28
LITTLE CLAY SAND, FRACTURE ROCK		93	122	29
SAND, FRACTURE ROCK LITTLE CLAY		122	153	31
SAND, FRACTURE ROCK		153	184	31
SAND, GRAVEL		184	224	40

Date started OCTOBER 29, 1992
Date completed NOVEMBER 5, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		

8. WELL CONSTRUCTION
Depth Drilled 224 Feet Depth Cased 224 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
9 7/8	0	224

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10.79	.188	0	224

Perforations:
Type perforation SINGLE
Size perforation 1/8 SLOT
From 0 feet to 186 feet BLANK
From 186 feet to 224 feet PERF
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 180 FEET
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 180 feet to 224 feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION CO (Contractor)
Address 9955 NORTH VIRGINIA ST (Contractor)
RENO, NV. 89506
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1541
Signed Dan Stamper (By driller performing actual drilling on site or contractor)
Date DECEMBER 11, 1992

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627