WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39914
Permit No.
Basin 87

NOTICE OF INTENT NO. 21179

1. OWNER WASHOE COUNTY UTILITY DIVISION
MAILING ADDRESS 1195 B. CORPORATE BLVD
RENO, NV. 89502
ADDRESS AT WELL LOCATION WASHOE COUNTY UTILITY 1195 B. CORPORATE BLVD
RENO, NV 89502

2. LOCATION NW ¼ SW ¼ Sec. 16 T. 19 (N)S R. 20 E. WASHOE County
PERMIT NO. W371 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL and CLAY		0	10	10
GRAVEL SAND FRACTURE ROCK, CLAY		10	102	92
GRAVEL SAND FRACTURE ROCK, CLAY		102	138	36

Date started NOVEMBER 9, 1992
Date completed NOVEMBER 25, 1992

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
450	34 FEET	68

8. WELL CONSTRUCTION
Depth Drilled 138 Feet Depth Cased 138 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
17½ Inches		0 Feet	138 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	33.38	.250	0	138

Perforations:
Type perforation Johnson HYCAP WIRE WRAP
Size perforation SCREEN
From 78 feet to 68 feet BLANK
From 68 feet to 138 feet SCREEN
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 138 feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION CO (Contractor)
Address 9955 NORTH VIRGINIA ST (Contractor)
RENO, NV. 89506
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1541
Signed Dan Tramper (By driller performing actual drilling ~~on-site or contractor~~)
Date DECEMBER 11, 1992

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627