WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39916
Permit No.
Basin 87

NOTICE OF INTENT NO. 21628

1. OWNER Groundwater Technology
MAILING ADDRESS 1401 Halyard Dr. Suite 140
West Sacramento, Ca. 95691

ADDRESS AT WELL LOCATION Dyn Air/ RFFC
355 S. Rock Blvd.
Reno, NV.

2. LOCATION NE ¼ SW ¼ Sec. 17 T 19N N/S R 20 E Washoe County
PERMIT NO. M/O 425A MW 5
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
A/C		0	1	1
Silty Sand		1	5	4
Gravelly Sand		5	8	3
Gravelly Coarse Sand		8	11	3
Sandy Gravel		11	20	9

Date started November 17 1992, 19
Date completed November 17 1992, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 19 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 5/16 Inches	0 Feet	20 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 40	0	19
End Cap PVC				
Lock In Cap PVC				

Perforations:
Type perforation Factory Sawed Slot
Size perforation .020
From 5 feet to 19 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 4
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 4 feet to 19.5 feet

9. WATER LEVEL
Static water level 12.0 feet below land surface
Artesian flow not known G.P.M. P.S.I.
Water temperature NK °F Quality NK

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling Inc. Contractor
Address P.O. Box 12370 Contractor
Reno, NV. 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources 908 the on-site driller
Signed [signature] By driller performing actual drilling on site or contractor
Date November 30, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627