

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20099

1. OWNER Gary Laack ADDRESS AT WELL LOCATION 7430 Brian Canyon Rd  
MAILING ADDRESS 1102 N Curry St Carson City, Nv 89703 Parcel - C of Map 11-85  
2. LOCATION SW 1/4 SW 1/4 Sec 23 T-26 R-16 N/S R. 19 E Washoe County  
PERMIT NO. 55-292-31 - Washoe Valley - Franktown Rd Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	12	12
Weathered granite brown - soft		12	42	30
Black & white granite med hard		42	61	
Black & white granite med hard		61	90	29
Black & white granite rock hard		90	238	148
Black & white granite hard with various fractures		238	340	102
Black & white granite med hard with brown volcanic rock - soft		340	379	39
Black & white granite hard w/ various fractures		379	423	44
T.D. 423 ft				

8. WELL CONSTRUCTION  
Depth Drilled 423 Feet Depth Cased 423 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 Feet To 100 Feet  
10 1/2 Inches  
From 100 Feet To 423 Feet  
8 1/2 Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	423

Perforations:  
Type perforation factory  
Size perforation 3/32 x 3  
From 383 feet to 403 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 100 ft  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 100 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Aqua Drilling & Well Service, Inc Contractor  
Address 625 Spice Islands Dr Suite L Contractor  
Sparks, Nv 89431  
Nevada contractor's license number issued by the State Contractor's Board 15291  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509  
Signed Roger M. Thrall  
By driller performing actual drilling on site or contractor  
Date 8/4/92

Date started 7/22/92  
Date completed 8/19/92

7. WELL TEST DATA

TEST METHOD:  Bail  Pump  Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
test pumped	6	406	3
			<u>N39.229885</u>
			<u>W119.823729 N14207</u>
			<u>Deepened into</u>
			<u>NDI 6/19/64</u>