WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39942
Permit No.
Basin 91

NOTICE OF INTENT NO. 20002

Consultant:
1. ~~OWNER~~ Summit Engineering Corporation
MAILING ADDRESS 5405 Mae Anne Ave.
Reno, NV. 89523

Client:
~~ADDRESS AT WELL LOCATION~~ Boomtown Hotel & Casino
I-80 & Garson Rd.
Well # 7 Reno, NV.

2. LOCATION ¼ SO ¼ Sec. 16 T. 19 N/S R. 18 E Washoe County
PERMIT NO. M/O - 504B (Issued by Water Resources) 381-200-09 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown, Sandy Silt minor clay, dry		0	10	10
Brown, Silty SAnd, medium to coarse grained sand, dry		10	20	10
Brown, SAndy Gravel angular gravels to ½" diameter		20	30	10
Brown, Silty Sand		30	40	10
Brown, Sandy Gravel gravel to 1" diameter		40	50	10
Grey, Silty Sand		50	60	10

Date started 9/25/92, 19
Date completed 9/25/92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No Test			

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 40/60 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 5/16	Inches	0 Feet	12 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 40	0	12
2		Sch 40	0	40

Perforations:
Type perforation Machine Slotted
Size perforation 0.125 inch
From 12 feet to 37 feet
From 40 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 9'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 11/39 feet to 38/60 feet

9. WATER LEVEL
Static water level N/A feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV. 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed Gary O. Hedman (By driller performing actual drilling on site or contractor)
Date October 26, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627