WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39956
Permit No.
Basin 108

NOTICE OF INTENT NO. 22465

1. OWNER Gene Adrian
MAILING ADDRESS 506 Madden Ln
Yerington NV. 89447
ADDRESS AT WELL LOCATION Amanatt Dr.
Sunset Hills

2. LOCATION NE ¼ ¼ Sec 29 T 14 N/S R 25 E Lyon County
PERMIT NO. NA (Issued by Water Resources) 14-271-57 (Parcel No.) Sunset Hills (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty, Sandy Soil		0	3'	3
Sand, Silt & Small Gravel		3	18'	15
Sand, Clay & Gravel		18	32'	14'
Gravel & Clay With Boulders		18	67'	49'
Gravel & Clay		67	110'	43
Sand, Silt & Gravel	✓	110'	140	30'

Date started 11/20, 19 92
Date completed 11/24, 19 92

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air developed for Three Hours, From depth of 137 Feet.		

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 137' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	+0	[redacted]
		140'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	188	+1	136

Perforations:
Type perforation Torch Cut
Size perforation 3/16 x 5" x 6 Rows
From 116' feet to 136' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60' feet to 136' feet

9. WATER LEVEL
Static water level 63 feet below land surface
Artesian flow NA G.P.M. 60 P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address P.O. Box 599 (Contractor)
Silver Springs NV. 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed Nathaniel L. Leach (By driller performing actual drilling on site or contractor)
Date 12/9/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627