

OFFICE USE ONLY
 Log No. 39988
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22270

1. OWNER RICHARD SCOTT ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS GARDNERVILLE, NV 1878 MILKWEED
GARDNERVILLE, NV
 2. LOCATION SE 1/4 SW 1/4 Sec. 36 T. 13 N. R. 20 E. DOUGLAS County
 PERMIT NO. _____ Parcel No. 23-473-41 Subdivision Name WILDFLOWER

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY + COBBLES		0	46	46
GRAVEL + SAND		46	54	8
SANDY CLAY + GRAVEL		54	103	49
CLAY		103	112	9
SANDY CLAY + GRAVEL		112	137	25
CLAY		137	249	112
SANDY CLAY + GRAVEL		249	296	47
GRAVEL + COARSE SAND	✓	296	301	5
SANDY CLAY + GRAVEL	✓	301	329	28
GREY CLAY		329	340	11

8. WELL CONSTRUCTION
 Depth Drilled 340 Feet Depth Cased 340 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 340 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>340</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 290 feet to 330 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 340 feet

Date started 11-16, 1992
 Date completed 11-24, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>AIR</u>	<u>25+</u>	<u>2</u>

9. WATER LEVEL
 Static water level 199 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature WARM °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Pat J. Moore
 By driller performing actual drilling on site or contractor
 Date 11/24/92