WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39989
Permit No.
Basin 105

NOTICE OF INTENT NO. 22412

1. OWNER Mike Hickey (Builder)
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1938 Wildonlon Gardnerville NV

2. LOCATION SW ¼ SE ¼ Sec. 36 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) Parcel No. 23-472-49 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	10	10
Y4 Gravels		10	16	6
Cemented Gravels		16	25	9
Sandy Brown Clay		25	60	35
Gravels		60	75	15
Brown Soft Clay		75	160	85
Black & Red Volcanic Rock w/ Small Clay Seams	X	160	270	110
Gray Clay (Hard		270	460	190
Grey Gray Clay		460	495	35
Gray Clay Firm Some Small Drilling Brakes 2' & 3' Sand Seams		495	560	65
Sandy w/gravels w/water	XXX	560	600	40

Date started 10-28, 1992
Date completed 11-6, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	40	3 Hrs.

8. WELL CONSTRUCTION
Depth Drilled 600' Feet Depth Cased 600' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11¾ Inches	0' Feet	55' Feet
9⅞ Inches	55' Feet	600 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	~~[illegible]~~ 13.03	~~[illegible]~~ 188	0	600

Perforations:
Type perforation Mill Slot
Size perforation 3/2 x 3/32
From 160' feet to 180' feet
From 560' feet to 600' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55' feet to 600' feet

9. WATER LEVEL
Static water level 270 feet below land surface
Artesian flow G.P.M. 20' P.S.I.
Water temperature Cold °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name
Address A & H PUMP CO. 5551 Hwy. 50 East #3 Carson City, Nevada 89[illegible] [illegible]0459 883-4[illegible]
Contractor
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Bulter
By driller performing actual drilling on site or contractor
Date 11-9-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627