

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22311

1. OWNER R.O. Livestock / Store Safe Redlands ADDRESS AT WELL LOCATION No. Physical Address
 MAILING ADDRESS P.O. Box 2050 Deeded Ranch / Range Land
King City Ca. 93930

2. LOCATION N.W. 1/4 SW 1/4 Sec 29 T 13 N R 47 E Nye County
 PERMIT NO. Proof # 05736 / Cert. # 40676 Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	7	7
Black Clay		7	20	13
Brown clay		20	22	2
SAND		22	35	13
Brown clay		35	58	23
SAND		58	73	15
Brown Clay		73	85	12
Large gravel	✓	85	96	11
Black Clay		96	100	4

8. WELL CONSTRUCTION
 Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 50 Feet
10 Inches 50 Feet 100 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>13.99</u>	<u>1.203</u>	<u>+1</u>	<u>100</u>

Perforations:
 Type perforation Milled
 Size perforation 1/8 x 3
 From 20 feet to 80 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow ± 15 G.P.M. _____ P.S.I.
 Water temperature C °F Quality good

Date started 12-4 1992
 Date completed 12-7 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>No Test</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Waytek Drilling Co. Contractor
 Address 2220 Stone Dr Reno NV 89511 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 024521
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1374
 Signed Les Waytek
 By driller performing actual drilling on site or contractor
 Date 12-9-92

'92 DEC 14 P 3 07
 STATE ENGINEERS OFFICE