WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. A0016
Permit No. DOMESTIC
Basin 102-CHURCHILL V.

NOTICE OF INTENT NO. 20428

1. OWNER SMARTT BUCKNOR
MAILING ADDRESS 2960 E. 4th St. Reno, NV. 89503
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ SE ¼ Sec. 8 T. 17 N/S R. 25 E. LYON County
PERMIT NO. NA (Issued by Water Resources) 17-166-08 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt & Sand		0	36	36
Brown clay & Sand		36'	83'	47
Gummy Brown Clay		83'	137'	54'
Sand & Silt	✓	137	140	3'
Brown Clay		140	183'	43'
Sand & Silt	✓	183	190'	7'

'92 DEC 10 A11:34
STATE ENGINEER'S OFFICE

Date started 11/18, 1992
Date completed 11/23, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Developed Well For 5 Hrs At The Rate of 80 Gallon per Minute From 190' Ft.		

8. WELL CONSTRUCTION
Depth Drilled 190' Feet Depth Cased 190' Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 190' Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	188	1'	190'

Perforations:
Type perforation Air Star Wheel Preforator
Size perforation 3/16 x 1" x 6 Rows
From feet to feet
From 140' feet to 160' feet
From feet to feet
From 170' feet to 190' feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 70'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 70' feet to 190' feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow NA G.P.M. 80 P.S.I.
Water temperature Cold °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address Po. Box 599 (Contractor)
Silver Springs NV. 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed [signature] By driller performing actual drilling on site or contractor
Date 12/9/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627