

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19981

1. Consultant: Simon Hydro-Search Client: Washoe Keystone Fuel
 MAILING ADDRESS: 5250 S. Virginia Suite # 280 ADDRESS AT WELL LOCATION: Fourth Street
Reno, NV. 89502 Reno, NV.
 2. LOCATION: NE 1/4 SE 1/4 Sec. 10 T 19N N/S R. 19 F Washoe County
 PERMIT NO. M/O 288A MW-6 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other: Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill, cobbles up to 7" subrounded(5%)silty sand gravel, gravel-subrneded up to 3", coarse sand 40%silt		0	8	8'
Pieces of brick @ 7' As above w/40% stfff, plastic clay, sit damp		8	15	7'
Pieces of burnt wood/ charcoal @ 11' Silty sand, well sorted rounded, coarse grnd, 10-20% silt int. cobbles		15	18	3'
As above/ fn to coarse sand, silt, int. cobbles, subang to subrneded		18	20	2'
Fn grnd, silty sand, silt		20	23	3'
As above w/ cobbles&gravel boulders, inc cobbles		23	26	3'
Color change, cobbles, gravel w/fn grnd silty sand		26	28	2'
Cobbles&Gravel, rnded to subangr. silty sand, fn grnd		28	33.5	5.5'
AS above w/clay, plastic		33.5	35	1.5'
Same as 28-33.5, sand		35	38	3'
As above w/ coarse sand		38	39	1'

8. WELL CONSTRUCTION
 Depth Drilled 39' Feet Depth Cased 39' Feet
 HOLE DIAMETER (BIT SIZE)
 From 7 1/4" Inches To 0 Feet 25 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		Sch 40 PVC	0	14

Perforations:
 Type perforation Factory Sawn Slot x2
 Size perforation .020
 From 14 feet to 39 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 1.7' Bentonite 9.1 Neat Cement
 Cement Grout
 Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
 From 25 feet to 39 feet

9. WATER LEVEL
 Static water level 29' feet below land surface
 Artesian flow Not Known G.P.M. _____ P.S.I. _____
 Water temperature 66 °F Quality PH7.1 *EC=842uhmos/ km

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc.
 Address P.O. Box 12370
Reno, NV. 89510

Nevada contractor's license number 22549 issued by the State Contractor's Board
 Nevada driller's license number issued by the 908 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date December 14, 1992

Date started May 18, 1992, 19_____
 Date completed May 18, 1992, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
NO TEST			

DEC 24 AM 01
 STATE ENGINEERS