


WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY

Log No. 40041  
Permit No. \_\_\_\_\_  
Basin. 661



NOTICE OF INTENT NO. 16343

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE  
 MAILING ADDRESS PO BOX 29  
ELKO, NV 89803

2. LOCATION NW 1/4 NW 1/4 Sec 29 T 36 N 50 R 50 E EUREKA County  
 PERMIT NO. WATVER#M/O-441A Parcel No. N/A Subdivision Name N/A  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND, CARLIN, GRAVEL	0	0	125	125
GRAVEL, SAND	15 GPM	125	220	95
GRAVEL, SAND	45 GPM	220	360	140
GRAVEL	75 GPM	360	540	80
MUDSTONE		540	560	20

*Per Drilled Correspondence 1/11/93:*

*Dual Completion:*  
 ID #1 = 540'  
 TD #2 = 295'

*Bentonite Hole Plug*  
 3/8" minus, used to seal between tubes

*\* 1 3/4" casing is SCH 40 black pipe w/ flush joints.*

*\*\* SWL from TOC (3' stick-up) on 1/3/92 = #1 - 161.91'  
 #2 - 161.29'*

8. WELL CONSTRUCTION  
 Depth Drilled 560 Feet Depth Cased 540 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
12 1/4	0	50
6 1/2	50	220
6 3/4	220	560

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	38	.4375	0	50
1-3/4	3	SCH 40 *	0	540
2-3/4	3	SCH 40 *	0	295

Perforations:  
 Type perforation SLOT  
 Size perforation .025

From	feet to
540	560
295	255

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 540 TO 480 feet to 300 TO 240 feet

Date started DECEMBER 9, 1992  
 Date completed DECEMBER 10, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	75		

9. WATER LEVEL  
 Static water level 110 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING  
 Contractor  
 Address 2286 WEST 1500 SOUTH  
 Contractor  
SALT LAKE CITY, UT 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410

Signed John Herzig  
 By driller performing actual drilling on site or contractor

Date DECEMBER 11, 1992