WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 10047
Permit No.
Basin 109

NOTICE OF INTENT NO. 22416

1. OWNER Randy McConnville
MAILING ADDRESS 10 77 Cortez Gardnerville NV.
ADDRESS AT WELL LOCATION 10 Cortez Gardnerville

2. LOCATION SE ¼ NE ¼ Sec. 12 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. Issued by Water Resources
Parcel No. 23-234-12
Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ PVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Big Cobbles & Sand		0	15	15
Cemented Gravels		15	20	5
1/4 Gravels		20	35	15
Firm Brown Clay		35	60	25
Brown Clay w/ Cemented Gravels		60	85	25
1/4" to 1/2" gravels		85	115	30
Firm Brown Clay w/ Small Gravels		115	180	65
Hard Broken		180	240	60
Gummy Brown Clay		240	270	30
Hard Broken rock Gravels	xxx	270	325	55

Date started 12-8, 1992
Date completed 12-10, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12-15	40'	2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 325' Feet Depth Cased 325' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11¼" Inches	0 Feet	55' Feet
10" Inches	55 Feet	325' Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	325'

Perforations:
Type perforation Mills Lot
Size perforation 2½ x 3/32
From 285 feet to 325 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 325' feet

9. WATER LEVEL
Static water level 260' feet below land surface
Artesian flow G.P.M. 12-15 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. Contractor
Address 5551 Hwy. 50 East #5 Carson City, Nevada 89[illegible] 883-0459 883-4[illegible] 885-188[illegible] Contractor

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed [signature] By driller performing actual drilling on site or contractor
Date 12-10-92

RECEIVED JAN 13 1993 STATE ENGINEER'S OFFICE

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627