WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40087
Permit No.
Basin 101

NOTICE OF INTENT NO. 21463

1. OWNER Lester Tyler
MAILING ADDRESS P.O. Box 1673
Fallon, NV 89407

ADDRESS AT WELL LOCATION 3003 Indian Lakes Road
Fallon, NV 89406

2. LOCATION NW ¼ NW ¼ Sec. 28 T 19 N/S R 29 E Churchill County
PERMIT NO. (Issued by Water Resources) | Parcel No. 07-391-35 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	18	18
Fine Green Sand		18	21	3
Black Sandy Clay		21	43	22
Coarse Black Sand		43	61	18
Bla ck SaNDY Clay		61	65	4
Green Coarse Sand		65	71	6
Green Clay		71	86	15
Green Coarse Sand		86	91	5
Brown Fine Sand		91	94	3
Brown Clay		94	111	17
Brown Coarse Sand	X	111	120	9

JAN - 8 1993 STATE ENGINEER'S OFFICE

Date started December 31, 19 92
Date completed December 31, 19 92

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	120 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	120

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 116 feet to 119 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 12' 4" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons (By driller performing actual drilling on site or contractor)
Date Jan 6, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627