WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. A0194
Permit No.
Basin 087-

NOTICE OF INTENT No.

1. ~~OWNER~~ Consultant: Groundwater Technology Inc.
MAILING ADDRESS 1401 Halyard Suite 140
West Sacramento, CA. 95691

Client: Shell Oil Co.
~~ADDRESS AT WELL LOCATION~~ 315 Nugget Ave.
Sparks, NV.

2. LOCATION NW ¼ NW ¼ Sec. 9 T 19N N/S R 20 E Washoe County
PERMIT NO. M/O-282D (Issued by Water Resources) | Parcel No. | Tank Farm (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty sand dk brown		0	3	3
Poorly graded sand w/ gravel		3	13.5	10.5
Silty sand(Dk green)		13.5	15.5	2
Clayey sand w/ gravel		15.5	20.6	5.1
Silty gravel w/ sand		20.6	34	13.4

Date started June 18, 1992, 19
Date completed June 19, 1992, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NO TEST			

8. WELL CONSTRUCTION
Depth Drilled 34 Feet Depth Cased 34 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 5/16 Inches	0 Feet	34 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		SCH 40 PVC	0	34

Perforations:
Type perforation slotted
Size perforation .020 inches
From feet to feet
From 14 feet to 34 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 11ft.
Placement Method: [ ] Pumped [X] Poured
Seal Type Bentonite
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout

~~Gravel~~ Sand Packed: [X] Yes [ ] No
From 11 feet to 34 feet

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow NA G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV. 89510
Nevada contractor's license number 22549 issued by the State Contractor's Board
Nevada driller's license number 923 issued by the Division of Water Resources, the on-site driller
Signed [signature] (By driller performing actual drilling on site or contractor)
Date January 12, 1993

'93 JAN 25 P1:57
STATE ENGINEERS OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627