WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40137
Permit No.
Basin 93

NOTICE OF INTENT NO. 18548

1. OWNER Dale Kulm
MAILING ADDRESS 140 Sells
Sparks, Nevada

ADDRESS AT WELL LOCATION
Delia Dr.
Antelope Valley

2. LOCATION NW ¼ SW ¼ Sec. 26 T. 22 N/S R. 19 E. Washoe County
PERMIT NO. N/A (Issued by Water Resources) 079-450-18 (Parcel No.) Red Rock Est. #275 per 4 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	
Sand		3	15	
Brown sandy clay		15	22	
Clay & DG		22	40	
Sandy brown clay & DG		40	60	
Cemented Rock		60	80	
Cemented DG with clay		80	220	

Date started 11-8-92, 19
Date completed 11-9-92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx.	20	210	2

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
97/8 Inches		0 Feet	220 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
65/8	13	.188	-1	220

Perforations:
Type perforation Mill Slot
Size perforation 1/8" X 3"
From 160 feet to 180 feet
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50+
Placement Method: [X] Pumped [ ] Poured

Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow None G.P.M. None P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, Nevada 89507
Nevada contractor's license number issued by the State Contractor's Board 29064-C23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller (By driller performing actual drilling on site or contractor)
Date 12-18-92

93 JAN 29 P1:15 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627