

OFFICE USE ONLY
 Log No. 4014
 Permit No. _____
 Basin 102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22301

1. OWNER TENAYA Investment Co ADDRESS AT WELL LOCATION 2885
 MAILING ADDRESS PO. Box 279
Verdie Nevada 89439 RAMSBY CUTOFF
 2. LOCATION SW 1/4 SW 1/4 Sec. 35 T. 18 N/S R. 24 E. Lyon County
 PERMIT NO. NA 15-211-35 Parcel No. TENAYA-Lumas Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel And Dirt		0	4'	4'
Gravel And Clay		4'	38'	34'
TAN clay		34	121'	87'
Brown sticky Clay small AMT OF SAND		121'	159'	38'
Blue-Green Clay Very sticky		159'	180'	21'
Black Broken Shale and Clay seams mixed		180'	282'	102'
Broken Loose Shale, Black & Brown, color	✓	282	314'	32'

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
11" Inches 0 Feet 60' Feet
8 3/4" Inches 60 Feet 314' Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>188</u>	<u>+1</u>	<u>315'</u>

Perforations:
 Type perforation Air Perforator
 Size perforation 3/16 x 1 5 Rows 1" APART
 From _____ feet to _____ feet
 From 280' feet to 314' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 60' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 60' feet to 314' feet

9. WATER LEVEL
 Static water level 167 feet below land surface
 Artesian flow NA G.P.M. 20 P.S.I.
 Water temperature Cold °F Quality clear

Date started Jan 7, 1993
 Date completed Jan 18, 1993

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air Developed 4 hrs.</u>		
<u>Tested At 20 GPM.</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Leach Drilling Inc Contractor
 Address PO. Box 599 Contractor
Silver Springs NV. 89429
 Nevada contractor's license number 0031841
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1740
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date Jan 27 1993