

OFFICE USE ONLY
 Log No. 40145
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22271

1. OWNER RICHARD SCOTT ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS GARDNERVILLE, NV 1922 CURRANT CT.
GARDNERVILLE, NV
 2. LOCATION SE 1/4 SE 1/4 Sec 35 T. 13 N. R. 20 E DOUGLAS County
 PERMIT NO. 23-473-47 Parcel No. _____
WILDFLOWER Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other rod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY w/ GRAVEL		0	12	12
CLAY		12	137	125
SANDY CLAY w/ GRAVEL		137	151	14
GRAVEL		151	180	29
SANDY CLAY w/ GRAVEL		180	207	27
GRAY SANDY CLAY		207	272	65
GRAY CLAY		272	376	104
BASALT		376	387	11
GRAY SANDY CLAY		387	467	80
SAND	✓	467	473	6
GRAY SANDY CLAY		473	477	4
SAND	✓	477	482	5
GRAY SANDY CLAY		482	500	8
SAND + GRAVEL	✓	500	512	12
GRAY SANDY CLAY		512	515	3

'93 JAN 29 P 1:09
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 515 Feet Depth Cased 515 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 500 Feet
5 5/8 Inches 500 Feet 515 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>500</u>
<u>5</u>	<u>10</u>	<u>.188</u>	<u>495</u>	<u>515</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 460 feet to 500 feet
 From 495 feet to 515 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 500 feet

9. WATER LEVEL
 Static water level 162 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature WARM °F Quality GOOD

Date started 11-25, 1992
 Date completed 12-11, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>AIR</u>	<u>15</u>	<u>5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Paul J. Murray
 By driller performing actual drilling on site or contractor
 Date 12/11/92