



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **10336**

1. OWNER **WILLIAM + DONNA NELSON** ADDRESS AT WELL LOCATION **MARBLE + CICCHI SANDY VALLEY**
 MAILING ADDRESS _____

2. LOCATION **NW 1/4 SW 1/4 Sec 26 T. 24 S N/S R. 56 E CLARK** County
 PERMIT NO. **580-250-069** Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOAM		0	3	3
CALICHE		3	10	7
CLAY		10	45	35
CALICHE		45	49	4
CLAY		49	55	6
CALICHE		55	58	3
CLAY		58	68	10
CALICHE	T.D.	68	73	5
CLAY		73	85	12
CALICHE	W.B.	85	91	6
CLAY		91	112	21
CALICHE	W.B.	112	134	12
CLAY		134	140	6

8. WELL CONSTRUCTION
 Depth Drilled **140** Feet Depth Cased **140** Feet

HOLE DIAMETER (BIT SIZE)
 From **12 1/4** Inches To **140** Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
 Type perforation **FACTORY SAW CUT**
 Size perforation **8 INCH BY 3 INCH**
 From **140** feet to **120** feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **140** feet to **50** feet

9. WATER LEVEL
 Static water level **65** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **COOL** °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **GREAT BASIN DRILLING** Contractor
 Address **H.C.R. 78 BOX 80358** Contractor
PAHRUMP NV. 89041
 Nevada contractor's license number issued by the State Contractor's Board **30880**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1573**
 Signed **Connie Brown**
 By driller performing actual drilling on site or contractor
 Date **11-4-92**

Date started **11-2**, 19**92**
 Date completed **11-4**, 19**92**

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
RECEIVED		
NOV 10 1992		
Div. of Water Resources Branch Office - Las Vegas, NV		

