

CROCKETT WITBIN
 PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 40184
 Permit No. 56272
 Basin 212

NOTICE OF INTENT NO. 10511

1. OWNER Dominick Riitano ADDRESS AT WELL LOCATION N/A
 MAILING ADDRESS 830 E. Sahara
Las Vegas, Nevada 89104
 2. LOCATION NW 1/4 NE 1/4 Sec 8 T. 19S N/S R. 60 E Clark County
 PERMIT NO. 56272 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		0	9	
Cemented Gravel		9	16	
Clay Gravel		16	95	
Cemented Gravel		95	210	
Clay Gravel		210	290	
Gravel & Water	xx	290	350	

8. WELL CONSTRUCTION
 Depth Drilled 350 Feet Depth Cased 350 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 55 Feet
9 7/8 Inches 55 Feet 350 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8"</u>	<u>16.94</u>	<u>.188</u>	<u>+2</u>	<u>350</u>

Perforations:
 Type perforation Factory
 Size perforation 3/16 x 8 row
 From 310 feet to 330 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 235 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor

Date started October 20/92, 19_____
 Date completed October 23/92, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Address 3035 S. Torrey Pines Contractor
Las Vegas, Nevada 89102
 Nevada contractor's license number 10062
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 552
 Division of Water Resources, the on-site driller
 Signed V.A. Dimick
 By driller performing actual drilling on site or contractor
 Date 10-24-92

RECEIVED
 OCT 29 1992
 Div. of Water Resources
 Branch Office - Las Vegas, NV

