

OFFICE USE ONLY
 Log No. 40300
 Permit No. 105
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22417

1. OWNER Eaglehand Const ADDRESS AT WELL LOCATION 243 Phumb
 MAILING ADDRESS 1307 Yellow Jacket CE. Gardnerville NV
Gardnerville NV
 2. LOCATION SE 1/4 NE 1/4 Sec 2 T 19 S R 19 E Douglas County
 PERMIT NO. 19-060-49 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BRN SAND SOME CLAY		0	5	
BRN SAND GRAVEL		5	14	
JG SOME SANDY BRN CLAY		14	40	
JG W SANDY BRN CLAY		46	70	
JG SOME SANDY BRN CLAY		70	90	
JG W SANDY BRN CLAY		90	115	
JG SOME SANDY BRN CLAY	WB	115	133	
JG W SANDY BRN CLAY	WB	133	140	

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10" Inches 0 Feet 140 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		188	0	140

Perforations:
 Type perforation FACTORY
 Size perforation 3/32" x 3"
 From 140 feet to 120 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100'
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 140' feet to 100' feet

9. WATER LEVEL
 Static water level 36' feet below land surface
 Artesian flow G.P.M. 35+ P.S.I.
 Water temperature 60.0 °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
A & H PUMP CO.
 Name 5551 Hwy. 50 East
Carson City, Nevada 89
 Address 883-0450 883-40
885-1880
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1535
 Signed Prodd W. Plumb
 By driller performing actual drilling on site or contractor
 Date 2-2-93

Date started 1-28 19 93
 Date completed 1-29 19 93

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>35+</u>		<u>1.5 hrs</u>

93 FEB 16 P 2:57
 RECEIVED
 STATE ENGINEERS OFFICE