

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY

Log No. 210354
 Permit No. 55459
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO.10685

1. OWNER Greg Smith ADDRESS AT WELL LOCATION N/A
 MAILING ADDRESS 4645 Tee Pee
Las Vegas, Nv. 89129
 2. LOCATION NW 1/4 NE 1/4 Sec 6 T 20S N/S R 60 E Clark County
 PERMIT NO. 55459 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		0	3	
Clay & Gravel		3	95	
Cemented Gravel		95	130	
Clay & Gravel		130	260	
Boulders		260	290	
Cemented Gravel		290	315	
Boulders		315	375	
Clay & Gravel		375	505	
Gravel & Water	xx	505	558	

8. WELL CONSTRUCTION
 Depth Drilled 558 Feet Depth Cased 558 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4" Inches 0 Feet 70 Feet
9 7/8" Inches 70 Feet 558 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8"</u>	<u>16.94</u>	<u>.188</u>	<u>+2</u>	<u>558</u>

Perforations:
 Type perforation Factory
 Size perforation 3/16 x 8 row
 From 5.18 feet to 538 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 70
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

RECEIVED

DEC 15 1992

Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level 428 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 12/5/92 19____
 Date completed 12/10/92 19____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick Contractor
 Address 3035 S. Torrey Pines
Las Vegas, Nev. 89102
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed Vernon H. Dimick
 By driller performing actual drilling on site or contractor
 Date 12-10-92