

OFFICE USE ONLY
 Log No. 40357
 Permit No. 58090
 Basin 212

#3
 PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11965

1. OWNER City of North Las Vegas ADDRESS AT WELL LOCATION Alexander near Valley Drive
 MAILING ADDRESS P.O. Box 4086 North Las Vegas, NV 89036
 2. LOCATION NW 1/4 NE 1/4 Sec. 7 T. 20 R. 61 E. Clark County
 PERMIT NO. 58090T Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Caly & caliche		0	45	45
Clay & gravel		45	55	10
Brown clay		55	252	197
Sand & gravel		252	295	43
Brown clay		295	700	405
Sand & gravel		700	910	210
Sand		910	925	15
Brown clay		925	950	25

8. WELL CONSTRUCTION
 Depth Drilled 950 Feet Depth Cased 930 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
32 Inches 0 Feet 103 Feet
24 Inches 103 Feet 950 Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
26	110	.375	+1	103
16	62.57	.375	+3	930

Perforations:
 Type perforation Screen
 Size perforation .310 Louvres
 From 700 feet to 910 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 103 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 0 feet to 950 feet

RECEIVED
 FEB 08 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV

RECEIVED
 MAR 22 11:14
 STATE ENGINEERS OFFICE

9. WATER LEVEL
 Static water level 213 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started Oct. 8, 1992
 Date completed Jan. 28, 1993

7. WELL TEST DATA

	TEST METHOD: <input type="checkbox"/> Bailor <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1/14/93	2565	121.4	24 hrs.

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name THOMPSON DRILLING CO., INC. Contractor
 Address 4185 West Harmon Contractor
Las Vegas, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board 4286A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 290
 Signed Richard K. Thompson
 By driller performing actual drilling on site or contractor
 Date February 4, 1993