WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40362
Permit No.
Basin

NOTICE OF INTENT NO. 8380

1. OWNER Nancy Walker
MAILING ADDRESS Same
ADDRESS AT WELL LOCATION 216 Madge 89110

2. LOCATION NW ¼ SW ¼ Sec. 34 T. 20S N/S R. 62 E. Clark County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 2 | |
| Gravel & Sand | | 2 | 35 | |
| Gravel & Sand, Water | x | 35 | 45 | |
| Clay Gravel | | 45 | 105 | |
| Gravel & Water | x | 105 | 115 | |
| Clay | | 115 | 160 | |
| Gravel, Sand, Water | x | 160 | 200 | |

RECEIVED
DEC 10 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11/11/92, 19
Date completed 11/13/92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12 1/4" Inches | 0 Feet | 200 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8" | 16.94 | .188 | +2 | 200 |

Perforations:
Type perforation Factory
Size perforation 3/16" x 8 row
From 160 feet to 184 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100-200 feet to feet

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 3035 S. Torrey Pines (Contractor)
89102
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick
By driller performing actual drilling on site or contractor
Date 12-7-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627