

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 8466

1. OWNER LINDA ROSEK ADDRESS AT WELL LOCATION WIGWAM & CIMMARON
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 SW 1/4 Sec. 16 T. 23 N/S R. 60 E CLARK County
 PERMIT NO. 56052 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY, ROCKS AND GRAVEL		0	20	20
CMT. GRAVEL W/STKS		20	180	160
CLAY + GRAVEL				
CMT. GRAVEL W/STKS		180	350	170
STKS OF SANDSTONE				
LIME STONE		350	370	20
CMT. GRAVEL W/STKS		370	410	40
OF SANDSTONE				
SANDSTONE		410	580	170
LIMESTONE		580	640	60
SANDSTONE		640	650	10
CMT. GRAVEL		650	800	150

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From 1 3/4 Inches To 800 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8.78</u>	<u>16.94</u>	<u>1.188</u>	<u>1</u>	<u>800</u>

Perforations:
 Type perforation FACTORY
 Size perforation 1/2 x 3/12
 From 730 feet to 740 feet
 From 760 feet to 780 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 800 feet

RECEIVED
 FEB 18 1993
 Div. of Water Resources
 Branch Office Las Vegas, NV

Date started 1-27 1993
 Date completed 2-3 1993

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 6.30' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name DESERT DRILLING Contractor
 Address 6475 GARY AVE Contractor
LAS VEGAS, NV 89131
 Nevada contractor's license number issued by the State Contractor's Board 34274
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594
 Signed Timothy Conner
 By driller performing actual drilling on site or contractor
 Date 2-12-93