WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

14 Book

OFFICE USE ONLY
Log No. 40432
Permit No.
Basin 162

NOTICE OF INTENT NO. 11577

1. OWNER Orville Crask
MAILING ADDRESS
ADDRESS AT WELL LOCATION Lot 27 Janet St

2. LOCATION NW ¼ SW ¼ Sec. 33 T. 19S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 27-831-27 (Parcel No.) Rancho Del Sol (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	8	8
Caliche		8	10	2
Clay		10	34	24
Caliche		34	36	2
Clay		36	56	20
Caliche	WB	56	58	2
Clay		58	68	10
Caliche	WB	68	70	2
Clay		70	84	14
Caliche	WB	84	86	2
Clay		86	92	6
Caliche	WB	92	93	1
Clay		93	112	9
Caliche	WB	112	114	2
Clay		114	127	13
Caliche	WB	127	129	2
Clay		129	136	6
Caliche	WB	135	137	2
Clay		137	140	3

RECEIVED
JAN 26 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 1-21, 1993
Date completed 1-23, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Factory Saw Cut
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Great Basin Drilling
Address (Contractor) HCR 78 Box 80368
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 1-23-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627