WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40461 in Book
Permit No.
Basin 162

NOTICE OF INTENT NO. 10475

1. OWNER Grant Uptain
MAILING ADDRESS
ADDRESS AT WELL LOCATION 701 W. Black St.

2. LOCATION SW ¼ NW ¼ Sec. 9 T. 20-S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 35-172-07 (Parcel No.) Cal Vegas Ranchos Unit D (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown clay/caliche		4	12	8
Brown clay	X	12	53	41
Brown clay/caliche		53	108	55
Limestone		108	112	4
Brown clay/caliche	X	112	140	28

RECEIVED
FEB 03 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started January 26, 1993
Date completed January 26, 1993

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	140 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Torch Cut
Size perforation ¼ in. width 8 in. long
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 34 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jim Pike Well Drilling (Contractor)
Address P. O. Box 56 (Contractor)
Pahrump, Nevada 89041
Nevada contractor's license number issued by the State Contractor's Board 17563
Nevada ~~driller's~~ license number issued by the Division of Water Resources, the ~~on-site driller~~ 1324
Signed (By driller performing actual drilling on site or contractor)
Date January 28, 1993

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627