



**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER NELSON STRANCH ADDRESS AT WELL LOCATION UNIT F LOT 143 HORN ST. Pahrump  
 MAILING ADDRESS.....  
 2. LOCATION SW 1/4 NW 1/4 Sec. 17 T. 20 S N/S R. 53 E Nye County  
 PERMIT NO. 36-281-11 Parcel No. CAL-VEGAS RANCHOS Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	8	8
CALICHE		8	12	4
CLAY		12	36	24
CALICHE		36	42	6
CLAY		42	55	13
CALICHE	W.B.	55	60	5
CLAY		60	75	15
CALICHE	W.B.	75	78	3
CLAY		78	88	10
CALICHE	W.B.	88	95	7
CLAY		95	118	23
CALICHE	W.B.	118	123	5
CLAY		123	130	7
CALICHE	W.B.	130	135	5
CLAY		135	140	5

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 140 Feet  
 Inches..... Feet..... Feet  
 Inches..... Feet..... Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 3/8	16.94	.188	0	140

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 8 INCH 18Y 3 INCH  
 From 140 feet to 120 feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 140 feet to 50 feet

RECEIVED  
 JAN 05 1993  
 DIVISION OF WATER RESOURCES  
 Pahrump Office - LAS VEGAS, NV

Date started 12-17 1992  
 Date completed 12-21 1992

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL  
 Static water level 4.2 feet below land surface  
 Artesian flow..... G.P.M..... P.S.I.  
 Water temperature COOL °F Quality.....

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING Contractor  
 Address HCR 78 BOX 80358 Contractor  
PAHRUMP NV. 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 12-21-92