WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

EBP-1

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40545
Permit No.
Basin 212

NOTICE OF INTENT NO. 11961

1. OWNER Nevada Co-Generation
MAILING ADDRESS 420 N. Nellis Blvd Box A3-148
Las Vegas, NV 89110

ADDRESS AT WELL LOCATION Pabco site

2. LOCATION NW ¼ SW ¼ Sec 1 T 20 N/S R 63 E Clark County

PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Hole cleaned out to bottom with air. The hole caved necessitating going to mud circulation. Massive lost circulation would not allow circulation of fluid in bore hole. Fluid level would rise to 120', therefore a tremie pipe was set at 147' and cemented to the surface with 200 sacks cement. All per verbal approval of Tom Gallagher. | | | | |

RECEIVED
FEB 08 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Sept. 9, 1992
Date completed Dec. 16, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 940 Feet Depth Cased NA Feet

HOLE DIAMETER (BIT SIZE)
Inches From Feet To Feet
Inches From Feet To Feet
Inches From Feet To Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | | | | |

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 West Harmon (Contractor)
Las Vegas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 856
Signed Richard K. Thompson (By driller performing actual drilling on site or contractor)
Date February 4, 1993

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627