WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40587
Permit No.
Basin 101

NOTICE OF INTENT NO. 22510

1. OWNER Dave & Julie Cunningham
MAILING ADDRESS 2350 Indian Lakes Road, Fallon, NV 89406
ADDRESS AT WELL LOCATION 2350 Indian Lakes Road, Fallon, NV 89406

2. LOCATION NE ¼ SE ¼ Sec. 9 T. 19 N/X R. 29 E. Churchill County
PERMIT NO. (Issued by Water Resources) 007-391-39 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	6	6
Brown Clay		6	11	5
Fine Brown Sand		11	31	20
Fine Green Sand		31	34	3
Black Sandy Clay		34	50	16
Black COarse Sand		50	58	8
Black Sandy Clay		58	77	19
Green Fine Sand		77	81	4
Green & White Coarse Sand		81	91	10
Fine GReen Sand		91	94	3
Brown Coarse Sand		94	101	7
Brown Sandy Clay		101	111	10
Brown COarse Sand	X	111	128	17

Date started January 30, 19 93
Date completed January 30, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 128 Feet Depth Cased 128 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	128 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	128

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 123 feet to 128 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 128 feet

9. WATER LEVEL
Static water level 21' 2" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons (By driller performing actual drilling on site or contractor)
Date Feb 3, 1993

STATE ENGINEER
'93 FEB 10 P2:28

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627