

OFFICE USE ONLY

Log No. 40629

Permit No. 87

Basin. 87

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

### WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21675  
UNITED PARCEL SERVICE

1. OWNER: Consultant: GERAGHTY & MILLER, INC. ADDRESS AT WELL LOCATION: 369 E. Glendale Sparks, NV

MAILING ADDRESS: 5270 Neil Road, Suite 101 Reno, NV 89502

2. LOCATION: NE 1/4 SE 1/4 Sec. 9 T 19N N/S R. 20 E Washoe County

PERMIT NO. M/O-377 MW-1 \* crn. Overmyer & Bering

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED:  New Well  Replace  Recondition  Deepen  Abandon  Other

4. PROPOSED USE:  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. WELL TYPE:  Cable  Rotary  PVC  Air  Other

6. LITHOLOGIC LOG

| Material   | Water Strata | From | To | Thick-ness |
|--|--------------|------|----|------------|
| ABANDONMENT:   |              |      |    |            |
| Static Waterlevel @  | 23           |      |    |            |
| Total Depth  | 32.5         |      |    |            |
| Equipment used:  |              |      |    |            |
| High pressure cement pump & mixer  |              |      |    |            |
| 31 ft 1 1/4" dia. Tremie pipe  |              |      |    |            |
| Electrick Jack Hammer  |              |      |    |            |
| Materials used:  |              |      |    |            |
| 16 sacks of Portland Cement II   |              |      |    |            |
| 4 sack Bentonite Powder  |              |      |    |            |
| 1 sack Ready Mix   |              |      |    |            |
| 1.) measure SWL 23 ft & TD 32.5 ft   |              |      |    |            |
| 2.) Glue threaded adapter to existing casing.  |              |      |    |            |
| 3.) Set Tremie pipe to bottom of casing.   |              |      |    |            |
| 4.) Pump neat cement from bottom to surface.   |              |      |    |            |
| 5.) Pull tremie, fill casing & attach from cement pump directly to casing.   |              |      |    |            |
| 6.) Pump cement @100 PSI squeezing cement through perforations into the surrounding formations. When pressure increases discontinue pumping. |              |      |    |            |
| 7.) Remove surface completion, cut casing below grade & patch cement.  |              |      |    |            |

8. WELL CONSTRUCTION

Depth Drilled.....Feet Depth Cased.....Feet

HOLE DIAMETER (BIT SIZE)

From To

Inches Feet Feet

Inches Feet Feet

Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <b>ABANDONED</b>   |                     |                         |             |           |

Perforations:

Type perforation.....

Size perforation.....

From.....feet to.....feet

From.....feet to.....feet

From.....feet to.....feet

From.....feet to.....feet

From.....feet to.....feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout

Depth of Seal.....

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No

From.....feet to.....feet

Date started..... 2-22-93 ..... 19.....

Date completed..... 2-22-93 ..... 19.....

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
|        |                               |              |
|        |                               |              |
|        |                               |              |
|        |                               |              |

9. WATER LEVEL

Static water level..... 23 ..... feet below land surface

Artesian flow..... G.P.M. .... P.S.I.

Water temperature..... °F Quality.....

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name... Wayne Drilling, INC. Contractor

Address... P.O. Box 12370 Contractor

..... Reno, NV 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources the on-site driller 923

Signed *Wayne Drilling, Inc.* By driller performing actual drilling on site or contractor

Date... March 13, 1993