

OFFICE USE ONLY
 Log No. 90044
 Permit No. 99
 Basin 1

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 211680

1. OWNER Tim Ebright ADDRESS AT WELL LOCATION 450 Rowel Circle
 MAILING ADDRESS 1280 Goldfield Red Rock, NV
Reno, NV 89506

2. LOCATION NW 1/4 NE 1/4 Sec. 23 T. 23 N/S R. 18 E Washoe County
 PERMIT NO. "NA" Parcel No. 78-123-04 Subdivision Name None at this time
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D.G. and Sand		0	20	
" "		20	35	
Brown D.G. and Sand		35	55	
" "		55	75	
White D.G. and Sand		75	100	
" "		100	120	
Cemented D.G.		120	160	
White D.G. and Sand		160	200	

'93 MAR -3 AIO:54
 STATE ENGINEERS UNIT #1

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches 0 Feet 200 Feet
 To _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation Factory Perf.
 Size perforation 1/8 x 3"
 From 160 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 ft. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 17' feet below land surface
 Artesian flow None G.P.M. _____ P.S.I. _____
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Dave Mc Ninch Contractor
 Address 8005 Mc Ninch Rd. Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 5437-C23
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730
 Signed Rerald Lee Morris
 By driller performing actual drilling on site or contractor
 Date 2/22-93

Date started February 8, 1993
 Date completed February 13, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Approx.</u>	<u>30</u>	<u>100</u>	<u>3</u>