WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40063
Permit No.
Basin 102

NOTICE OF INTENT NO. 23981

1. OWNER American Property Services, Inc.
MAILING ADDRESS 1317 Jones St.
Reno, Nevada 89503
ADDRESS AT WELL LOCATION 1225 East St.
Silver Springs Nv. 89429

2. LOCATION NW ¼ NW ¼ Sec. 13 T. 17 N/S R. 24 E. Lyon County
PERMIT NO. — (Issued by Water Resources) Parcel No. 17-231-04 Subdivision Name Tyler Sub #1

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine Brown Sand		0	2	2
Fine Brown sand + Some Brown clay		2	10	8
Fine To coarse Brown sand		10	60	50
Fine To coarse Gray sand	X	60	80	20
Fine To coarse Brown sand	X	80	134	54

'93 MAR -8 P12:42 RECEIVED STATE ENGINEERS OFFICE

Date started 3-1, 1993
Date completed 3-2, 1993

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18	2	2

8. WELL CONSTRUCTION
Depth Drilled 134 Feet Depth Cased 134 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	134 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	134

Perforations:
Type perforation Mill
Size perforation 5/8 X 3
From 114 feet to 134 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 134 feet

9. WATER LEVEL
Static water level 47 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ACE Drilling & Dev. (Contractor)
Address P.O. Box 668 (Contractor)
Silver Springs, Nv. 89429
Nevada contractor's license number issued by the State Contractor's Board 14299
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-5-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627