

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 40751
 Permit No. 212
 Basin 212

NOTICE OF INTENT NO. 10271

1. OWNER SOUTHLAND CORPORATION ADDRESS AT WELL LOCATION 7-11
 MAILING ADDRESS XXXXXX 7811 University 3414 Sahara
La Mesa, California Las Vegas, NV

2. LOCATION SW 1/4 SW 1/4 Sec 6 T 21 N 62 E BARK CLARK County
 PERMIT NO. M/O - 537
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. Well Abandonment LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Excavation 2'x2'x1' deep (and removal) of surface seal and well vault.				
Pressure grouted inside casing through perforations with neat cement. (~ 5% Bentonite powder)				
RECEIVED				
MAR 14 1993				
Div. of Water Resources Branch Office - Las Vegas, NV				

8. WELL CONSTRUCTION
 Depth Drilled 13 Feet Depth Cased 13 Feet

HOLE DIAMETER (BIT SIZE)
 From 6 1/2 Inches To 13 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>sch 40</u>	<u>0</u>	<u>13</u>

Perforations:
 Type perforation Slotted
 Size perforation 0.020 inch
 From 13 feet to 3 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 1 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 13 feet to 2 feet

9. WATER LEVEL
 Static water level 5.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Spectrum Exploration, Inc./ Terry Sump Contractor
 Address 1860 Obispo #Unit H Contractor
Signal Hill, CA

Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1872-M

Signed Terry Sump
 By driller performing actual drilling on site or contractor
 Date 3/26/93

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			