

OFFICE USE ONLY  
 Log No. 40768  
 Permit No. 24  
 Basin. T

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21798

1. OWNER Kurt and Jana Neuffer ADDRESS AT WELL LOCATION 755 Sky Canyon Dr  
 MAILING ADDRESS 755 Sky Canyon Dr  
Reno, Nv 89510

2. LOCATION NW 1/4 SW 1/4 Sec. 6 T. 21 N/S R. 21 E Washoe County Washoe  
 PERMIT NO. 076-190-21 - Palomino Valley  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Blow sand		0	26	26
D.G.		26	55	29
Medium hard D.G.		55	115	60
Hard D.G.		115	230	115
Medium hard D. G.		230	250	20
D.G. & black volcanic rock		250	280	30
D.G. & Black volcanic rock & little gray clay		280	295	15
D.G. & volcanic rock		295	338	43
T.D.				

8. WELL CONSTRUCTION  
 Depth Drilled 338 Feet Depth Cased 336 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 5/8</u> Inches	<u>0</u> Feet	<u>50</u> Feet
<u>8 1/2</u> Inches	<u>50</u> Feet	<u>338</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+2</u>	<u>336</u>

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3

From 296 feet to 316 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 336 feet

9. WATER LEVEL  
 Static water level 230 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 1/29/93, 19\_\_\_\_  
 Date completed 2/2/93, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
	<u>18+</u>	<u>2</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
 Contractor  
 Address 625 Spice Islands Dr Suite L  
 Contractor  
Sparks, Nv 89431

Nevada contractor's license number 15291  
 issued by the State Contractor's Board.

Nevada driller's license number issued by the 1862 / 1804  
 Division of Water Resources, the on-site driller.

Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date 2/3/93